



Linda S. Adams  
Secretary for  
Environmental Protection

# California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
<http://www.waterboards.ca.gov/sandiego>

April 12, 2010

In reply refer to:  
248441:adai

Ms. Kathleen Rosenow and Mr. Frank Spevacek  
PO Box 926  
Julian, CA 92036

Dear Ms. Rosenow and Mr. Spevacek:

**SUBJECT: STAFF ENFORCEMENT LETTER REGARDING REVIEW OF  
PINECREST PARK ANNUAL MONITORING REPORT**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) reviewed the July 2008 – June 2009 annual monitoring report submitted in accordance with Monitoring and Reporting Program No. 86-48 for the subject facility.

The following violation of Order No. 86-48 was identified in the submitted report:

Discharge Specification B of Order No. 86-48 for total dissolved solids, established at 600 milligrams per liter (mg/L), was violated on July 17, 2009 with a reported value of 625 mg/L.

Please be aware this violation subjects you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report due is the July 2009–June 2010 annual monitoring report, which is due by July 31, 2010.

<sup>1</sup> Under authority of California Water Code section 13350.

Ms. Rosenow and Mr. Spevacek  
Pinecrest Park

- 2 -

April 12, 2010

In the subject line of any response, please include the requested "in reply refer to" information located in the heading of this letter. Please contact Ms. Amanda Dai at 858-627-3977 or at [adai@waterboards.ca.gov](mailto:adai@waterboards.ca.gov) if you have any questions on this matter.

Sincerely,

*Robert Morris*

Robert W. Morris, P.E.  
Senior Water Resource Control Engineer  
Ground Water Branch

---

*California Environmental Protection Agency*

 Recycled Paper

01-01-11-11-11